Cap -Service entrance head Service thimbleye Service cable (3' cable for power service hook-up) -3" flat square washers 1 1/4" metal riser conduit Stainless steel bands (3' centers) Meter base (if required) Breaker box to be locked at door. -9 Breaker box required. Condulets and close nipples Feeder cable inside steel pole Ground wire to breaker box. Typical controller foundation Pole grounding lug Ground wire Underground feeder cable بات بین 3' minimum to 20' maximum Ground rod 4" cover -Conduit as specified on plans $\frac{1}{2}$ " conduit TYPE A

Notes:

No other conductors shall be run in the same conduit with electrical service cable.

For alternate method of service cable and ground wire entering breaker box, see standard SE-5.

ELECTRICAL SERVICE DETAILS
SIGNAL INSTALLATION
VIRGINIA DEPARTMENT OF TRANSPORTATION